

1. UTILITY MAPPING IS BASED ON DATA AVAILABLE IN BURLINGTON'S GIS DATA BASE. ALL UTILITIES DEPICTED IN THE DRAWINGS SHALL BE CONSIDERED

APPROXIMATE AND SHALL BE CONFIRMED IN THE FIELD. 2. ALL FORCEMAIN PIPING THAT IS REPLACED SHALL MEET PRESSURE RATED REQUIREMENTS IN THESE CONTRACT DOCUMENTS.

3. CONTRACTOR SHALL ADHERE TO EXCAVATION PERMIT REQUIREMENTS AND TRAFFIC CONTROL REQUIREMENTS PER THE CONTRACT DOCUMENTS. 4. THE CONTRACTOR SHALL MAKE EVERY EFFORT TO ALLOW ACCESS TO AND FROM DRIVEWAYS OR LOADING DOCK DOORS LOCATED ALONG THE ROUTE. OCCUPANTS SHALL BE NOTIFIED IN ADVANCE OF ANY CONSTRUCTION THAT WILL LIMIT ACCESS TO THEIR PROPERTY. THE CONTRACTOR SHALL RESTORE ALL

DISTURBED DRIVEWAYS AND SURFACES TO THEIR ORIGINAL CONDITION. 5. CONTRACTOR TO REMOVE AND RESET SIGNS AS REQUIRED FOR CONSTRUCTION. THE CONTRACTOR SHALL RESET ALL REMOVED SIGNS PRIOR TO THE END OF

6. CONTRACTOR SHALL ASSUME ALL BUILDINGS HAVE A MUNICIPAL SEWER CONNECTION. ANY SEWER LATERAL DISTURBED DURING CONSTRUCTION SHALL BE REPAIRED BY THE CONTRACTOR AT THE CONTRACTOR'S EXPENSE.

7. TRAFFIC CONTROL PLANS SHALL BE IN ACCORDANCE WITH MUTCD STANDARDS AND A PROFESSIONAL ENGINEER SHALL SIGN OFF ON TRAFFIC CONTROL PLANS

8.THE CONTRACTOR SHALL REMAIN OUTSIDE OF THE RAILROAD RIGHT OF WAY DURING CONSTRUCTION AND SHALL NOT OBSTRUCT THE RAILROAD RIGHT OF WAY

9. CLOSE COORDINATION IS REQUIRED WITH DPW WATER RESOURCES TO ENSURE CONTINUED OPERATION OF THE FLYNN AVE PUMP STATION. DPW WATER

RESOURCES CAN PROVIDE BYPASS PUMPING SERVICES DURING SOME WORK, AS LONG AS THE WORK DOES NOT REQUIRE MORE THAN 5 BUSINESS DAYS OF BYPASS PUMPING SERVICES, AS LONG AS THE PUMP STATION IS NOT OUT OF SERVICE DURING WET WEATHER THAT MAY INCREASE PUMP STATION FLOWS, AND AS LONG AS THE CONTRACTOR RESTORES THE FORCE MAIN TO OPERATIONAL CONDITION AT THE END OF EACH WORK DAY.

10. COORDINATION WITH THE RAILROAD WILL BE REQUIRED FOR THE DURATION OF ANY SUBSURFACE WORK THAT OCCURS WITHIN THE RAILROADS RIGHT OF WAY.

EXISTING UTILITIES

Manhole

Catch Basin

Combined Waste Water

s----- Sewage

s→ Storm Runoff

Pressurized Sewer

Water System Valves

Water Hydrants

Water Mains

Overhead Power

Underground Electric

Gas Line



REFERENCE MAP

1 in = 20 feet 100 ▼Feet



WATER RESOURCES DIVISION

234 Penny Lane Burlington, VT 05401 (802)-863-4501 water-resources@burlingtonvt.gov

LOCATION PLAN

FLYNN AVE

DESIGNED:	GAJ/AEW
DRAWN:	GAJ
CHECKED:	
DATE:	4/15/2022