



ADDENDUM #2 - Leddy Park Tennis Court Reconstruction

Date: February 11, 2020
To: All Bidders
From: Burlington Parks, Recreation & Waterfront
Re: Addendum #2 Responses to questions received

The following questions were received in accordance with the timeline and procedures outlined in the Leddy Park Tennis Court Reconstruction RFP:

1. What material specifications does the City require for the tennis court fence Posts and mesh?
 - a. Fence posts shall be ss 40 wt. Wire mesh shall be 2"x2"x9 ga. All components vinyl coated.
2. How many coats of paint are required for the courts acrylic surfacing?
 - a. A minimum of 2 coats of paint are required for each color and line paint.
3. Is there any update on lead testing of the handball courts?
 - a. City staff went and conducted a lead test of the central wall of the handball court. The test came back negative for lead. It is presumed that there is no lead on the newer components of the handball and squash courts that date to no earlier than 1996.
4. If a bidder does not submit pricing for all the alternates, will their bid be disqualified?
 - a. No, bids will not be disqualified if they do not include price quotes for the bid alts.
5. Commonly, telephone and light poles are treated with creosote. Does the City have requirements for the disposal of the light poles?
 - a. The City requires that the contractor dispose of the poles at an appropriate facility in accordance with State and Federal law.