

Comments from public works

- The curbing detail is not required
- The design aspects the City is requesting be followed include all other aspects of the design cross-section including the materials, depths of materials, and material specs provided. For instance, we will ask that a low-phosphorus bioretention soil mix be used and that it is separated from the gravel layer with a single layer of non-woven geotextile. Geogrid lining the bottom of the system is also essential for the long term functioning of the system. If the property owner is aware of any other drinking water or sewer line laterals which may be located proximate to the system then liner or blueboard insulation would also be requested, respectively.