

Hey Scott:

Here is the email from Steve Roy clarifying his earlier letter about wastewater capacity. Please let me know if you have any questions. thanks! -john

----- Forwarded message -----

From: **Steve Roy** <SRoy@burlingtonvt.gov>

Date: Thu, Jul 2, 2020 at 4:00 PM

Subject: FW: Water & Wastewater Allocation Request for 266 Queen City Park Road

To: john.caulo@gmail.com <john.caulo@gmail.com>

Hey John,

Thanks for your call yesterday afternoon. I pulled up our 11/26/19 allocation letter to you and have answers to questions raised in the second paragraph of this letter.

Organic Loading: This boilerplate language is meant to address capacity requests from users that could discharge high organic loads to our wastewater plants. This will not be an issue for the proposed Performing Arts Venue with flow primarily from bathrooms.

Combined Sewer Policy: While this policy is still in draft form the intent is to have new users remove stormwater input to offset proposed new wastewater flows. This policy applies to new flows over 1000 gpd (like Higher Ground) and requires either removing 0.5 sqft impervious per wastewater gpd request or if not technically feasible on-site then payment of a Combined Sewer Offset Mitigation fee equal to \$1.84 per gpd request. These funds are placed in a special account to be used for public combined sewer mitigation projects.

I believe that no stormwater from the Burton campus enters our combined sewer system, however the wastewater flows does plus is also upstream from an active Combined Sewer Overflow (CSO) point, so most likely payment of \$13,800 will satisfy our requirements.

Steve

Steve Roy, PE

Senior Water Resources Engineer

Burlington Public Works

53 Lavalley Lane

Burlington, VT 05401

C: 802.343.0125