

City of Burlington Bike Parking Standards Proposed Changes - 14.6.9

- Local Motion Recommended Edits -

Contact: Ross Saxton, Business Partnerships Manager

ross@localmotion.org, (802) 383-8400

Table 14.6.9-A - Minimum Bicycle Parking Requirements

Commercial

Retail sales and service

Long term: change from "1 per 20,000sf" to "1 per 12,000sf" (change aligns with APBP guidelines)

Short term: change from "1 per 5,000sf" to "1 per 2,000sf" (change aligns with APBP guidelines for general food sales/groceries. Makes sense for retail, as well, in downtown locations.)

Residential

Household Living/Multi-unit

Long term: change from "1 per 4 units" to "1 per 2 bedrooms" (change aligns closer to APBP standards. Champlain College follows "1 per 3 beds" guideline, for reference.)

Group Living/Fraternity, sorority, dormitory

Long term: change from "1 per 4 residents" to "1 per 3 residents" (For reference, Champlain College follows the "1 per 3 residents" guideline.)

Industrial

Long term: change from "1 per 20,000sf" to "1 per 10,000sf" (Approx. aligns to APBP guidelines)

Permitted, Public/Institutional uses

Schools, Grades 2-5

Long term: change measurement unit from sf to teachers and students. Long term parking be "1 per 7 employees" and "1 per 10 students [of planned capacity]" (change aligns with APBP guidelines)

Schools, Grades 6-12

Long term: change measurement unit from sf to teachers and students. Long term parking be "1 per 7 employees" and "1 per 10 students [of planned capacity]" (change aligns with APBP guidelines)

Recommended change for "f)"

Include highly-visible signage for long term parking within requirements