



INSPECTION SERVICES DIVISION



www.burlingtonvt.gov/DPW/Municipal-Agreement-Mission-Statement

Specific to the Burlington City Code of Ordinances – Chapter 8 and current adopted Vermont Fire and Building Safety Codes and Standards

CODE COMPLIANCE INFORMATION SHEET

DUMPSTER LOCATION

FIRE SAFETY SPECIFIC:

All dumpsters and containers with an individual capacity of 1.5 cu. yd. or more shall not be stored in buildings or placed within 10 ft. of combustible walls, openings, or combustible roof eave lines.