



INSPECTION SERVICES DIVISION



www.burlingtonvt.gov/DPW/Municipal-Agreement-Mission-Statement

Specific to the Burlington City Code of Ordinances – Chapter 8 and current adopted Vermont Fire and Building Safety Codes and Standards

CODE COMPLIANCE INFORMATION SHEET

GROUNDING ELECTRODE CONDUCTOR

****CALL BEFORE YOU POUR****

The National Electrical Code requires that the concrete encased steel be included in the grounding electrode system... This means that you must have, “an electrode encased by at least 50 mm (2 in.) of concrete, located horizontally near the bottom or vertically, and within that portion of a concrete foundation or footing that is in direct contact with the earth, consisting of at least 6.0 m (20 ft.) of one or more bare or zinc galvanized or other electrically conductive coated steel reinforcing bars or rods of not less than 13 mm (1/2 in.) of diameter, or consisting of at least 6.0 m (20 ft.) of bare copper conductor not smaller than 4 AWG. Reinforcing bars shall be permitted to be bonded together by the usual steel tie wires or other effective means. Where multiple concrete-encased electrodes are present at a building or structure, it shall be permissible to bond only one into the grounding electrode system.” This will require an inspection before you pour concrete. If this inspection does not take place, you will have to cut into the concrete to provide proof that this connection has been properly made.

